

Region 9 Enforcement Division 75 Hawthorne Street San Francisco, CA 94105

Inspection Date(s):	spection Date(s): January 30, 2024									
Time:	Entry: 1:20pm Exit: 2:45 pm									
Media:		Water								
Regulatory Program(s	s)	Clean Water Act Pretreatment								
Facility or Site Name:		Desoted	Desotec US LLC							
Facility/Site Physical		2523 M	2523 Mutahar St							
Location: Parker AZ 85344										
Mailing address:			2523 Mutahar St							
			AZ 85344							
Facility/Site Contact:		Russell		Title: Plant Manager						
		Phone:	(724) 761-6998	Email: Russell.Smith@desotec.com						
Receiving POTW Nam	ne:	Colorad	o River Sewage System Joi	nt Venture						
Address:		12501 A	gency Rd., Parker, AZ 8534	14						
NPDES #:		AZ0021	415							
Categorical Part/Subp	part:	Centrali	zed Waste Treatment							
NAICS:		562211								
SIC:		4953								
Facility/Site Personne	el Par	ticipating	in Inspection:							
	Name Affiliation Title Email									
Name	Aff	iliation	Title	Email						
Name Margaret Jeferson	Aff Desc		Title Product Management	Email Margaret.Jefferson@desotec.com						
		otec	Product Management Production Supervisor	-						
Margaret Jeferson	Desc	otec	Product Management Production Supervisor and Backup Emergency	Margaret.Jefferson@desotec.com						
Margaret Jeferson	Desc	otec	Product Management Production Supervisor	Margaret.Jefferson@desotec.com						
Margaret Jeferson	Desc	otec	Product Management Production Supervisor and Backup Emergency	Margaret.Jefferson@desotec.com						
Margaret Jeferson	Desc	otec	Product Management Production Supervisor and Backup Emergency	Margaret.Jefferson@desotec.com						
Margaret Jeferson Jarrod Caswell	Desc	otec	Product Management Production Supervisor and Backup Emergency	Margaret.Jefferson@desotec.com						
Margaret Jeferson Jarrod Caswell EPA Inspector(s):	Desc	otec	Product Management Production Supervisor and Backup Emergency Coordinator	Margaret.Jefferson@desotec.com Jarrod.Caswell@desotec.com						
Margaret Jeferson Jarrod Caswell EPA Inspector(s): Adam Howell	Desc Desc US E	otec otec EPA	Product Management Production Supervisor and Backup Emergency Coordinator Inspector Inspector	Margaret.Jefferson@desotec.com Jarrod.Caswell@desotec.com Howell.Adam@epa.gov						
Margaret Jeferson Jarrod Caswell EPA Inspector(s): Adam Howell Laila Hayani	Desc Desc US E	PA P	Product Management Production Supervisor and Backup Emergency Coordinator Inspector Inspector	Margaret.Jefferson@desotec.com Jarrod.Caswell@desotec.com Howell.Adam@epa.gov						
Margaret Jeferson Jarrod Caswell EPA Inspector(s): Adam Howell Laila Hayani POTW / Federal/State	Desc Desc US E US E	PA P	Product Management Production Supervisor and Backup Emergency Coordinator Inspector Inspector esentatives: Operations Manager	Margaret.Jefferson@desotec.com Jarrod.Caswell@desotec.com Howell.Adam@epa.gov Hayani.Laila@epa.gov						
Margaret Jeferson Jarrod Caswell EPA Inspector(s): Adam Howell Laila Hayani POTW / Federal/State Ashley Longanecker	Desc Desc US E US E	EPA EPA SJV	Product Management Production Supervisor and Backup Emergency Coordinator Inspector Inspector esentatives: Operations Manager	Margaret.Jefferson@desotec.com Jarrod.Caswell@desotec.com Howell.Adam@epa.gov Hayani.Laila@epa.gov crssjvopsmgr@gmail.com						
Margaret Jeferson Jarrod Caswell EPA Inspector(s): Adam Howell Laila Hayani POTW / Federal/State Ashley Longanecker	Desc Desc US E US E	EPA EPA SJV	Product Management Production Supervisor and Backup Emergency Coordinator Inspector Inspector esentatives: Operations Manager	Margaret.Jefferson@desotec.com Jarrod.Caswell@desotec.com Howell.Adam@epa.gov Hayani.Laila@epa.gov crssjvopsmgr@gmail.com 415-972-3475						
Margaret Jeferson Jarrod Caswell EPA Inspector(s): Adam Howell Laila Hayani POTW / Federal/State Ashley Longanecker	Desc Desc US E US E	EPA EPA SJV Laila Ha	Product Management Production Supervisor and Backup Emergency Coordinator Inspector Inspector esentatives: Operations Manager	Margaret.Jefferson@desotec.com Jarrod.Caswell@desotec.com Howell.Adam@epa.gov Hayani.Laila@epa.gov crssjvopsmgr@gmail.com 415-972-3475						
Margaret Jeferson Jarrod Caswell EPA Inspector(s): Adam Howell Laila Hayani POTW / Federal/State Ashley Longanecker	Desc Desc US E US E	EPA EPA SJV Laila Ha	Product Management Production Supervisor and Backup Emergency Coordinator Inspector Inspector esentatives: Operations Manager yani	Margaret.Jefferson@desotec.com Jarrod.Caswell@desotec.com Howell.Adam@epa.gov Hayani.Laila@epa.gov crssjvopsmgr@gmail.com 415-972-3475 Date: 3/26/2024						

Desotec US LLC

Inspection Date: 1/30/2024

SECTION I – INTRODUCTION

I.1 Purpose of the Inspection

The purpose of the inspection was to ensure compliance with pretreatment standards and applicable Federal regulations covering the discharge of wastewaters into publicly owned treatment works. The inspection consisted of a review of the process areas, chemical storage areas, and the wastewater treatment system.

SECTION II – FACILITY / SITE DESCRIPTION

II.1 Facility Description

Desotec US LLC (Desotec) operates a carbon regeneration facility on the Colorado River Indian Tribes (CRIT) reservation. This Desotec facility was formerly operated as Evoqua Water Technologies until Evoqua's carbon reactivation and slurry services was bought by the European company Desotec. The facility sends its wastewater to the publicly owned treatment works (POTW), Colorado River Sewage System Joint Venture (CRSSJV). It has a pretreatment permit with CRSSJV, and the plant manager sends wastewater pretreatment data to both CRSSJV and the CRIT on a monthly basis.

Desotec accepts spent carbon from across the country and reactivates it for commercial reuse. The facility accepts both hazardous and non-hazardous spent carbon, with a split of about one-third and two-thirds respectively. Suppliers of spent carbon must provide an analytical profile before it is considered for acceptance into the facility. The profiles are good for two years.

II.2 Wastewater Sources

Spent carbon is mixed from different sources. Water is added and the slurry is stored in tanks. The slurry is transferred to a furnace with 0% excess oxygen to ensure that the carbon doesn't burn. The slurry is subjected to progressively higher temperatures as it travels down through the furnace's four zones. The heat drives organic compounds and moisture out of the carbon, reactivating it. Hot gasses and vapor are treated before being release via an emissions stack. Part of the gas treatment system is a wet scrubber, which generates wastewater with a high concentration of organic compounds. This is the primary source of wastewater from the facility.

Other sources of wastewater can include wastewater from the cooling tower and cooling screw, rainwater falling within containment areas, and facility wash-down water. Floor drains throughout the facility also collect wastewater for pretreatment.

Desotec US LLC

Inspection Date: 1/30/2024

The facility previously used a boiler but has eliminated it from their system, so they no longer have boiler feed blowdown wastewater. The facility is also covered under a Multi-Sector General Permit (MSGP) for stormwater.

II.3 Wastewater Treatment

Wastewater is first sent to a first stage reaction tank for pH adjustment using NaOH. It is then sent to a reaction chamber followed by a flocculation mixing chamber where flocculants are added to separate out metals. Next, wastewater is sent to the clarifier, where solids settle to the bottom of the tank. Clean water goes to the clearwell chamber, followed by the filtration chamber before being tested and sent to CRSSJV.

Solid waste from the clarifier is pumped out to sludge chambers and sent to a sludge thickener tank. Thickened sludge is brought to the filter press to turn it into a filter cake, which is picked up by Clean Harbors for incineration off-site.

II.4 Compliance History

The plant manager stated that they have not violated their effluent limits since he began in 2021. In the event of an exceedance, he would immediately notify the CRSSJV team.

SECTION III – OBSERVATIONS

- 1. The operator noted that they observe higher TDS levels in the summertime due to increased cooling needs for the cooling tower.
- 2. The outside walls of the sludge chamber showed precipitate buildup, primarily around the piping system that is seen in Photos 3 and 4.

SECTION IV – AREAS OF CONCERN

The presentation of areas of concern does not constitute a formal compliance determination or violation.

- 1. The 55-gallon tanks of metal ion precipitants and coagulants had their labels facing inward towards each other, making them difficult to read.
- 2. It is unclear what the sludge chamber piping system carries and what the precipitate is on the outside of this piping system. Please provide a response as to the purpose of this piping system and a description of the precipitate.

SECTION V – DOCUMENTS REQUESTED/REVIEWED DURING INSPECTION

The EPA inspectors reviewed Desotec's monitoring and reporting records, which are filed electronically.

APPENDICES

Appendix 1 – Inspection checklist

Appendix 2 – Photograph Log

Appendix 1- INSPECTION CHECKLIST

I. GENERAL

Facility Type	🗵 Categorical IU 🗌 Significant IU 🗀 Zer	o Discharge
racility Type	☐ Other	
Inspection Type	Pretreatment Compliance Inspection (no	n-sampling)
inspection type	☐ Pretreatment Compliance Inspection (Sa	ampling)
Weather		
⊠ Dry □	☐ Rain	
⊠ Clear □	☐ Recent Rains	
☐ Overcast ☐]	
Was facility notified in a	dvance?	Yes ⊠ No □
Presented credentials?		Yes ⊠ No □
Notes:		

II. RECORDS AND REPORTS REVIEW						
RECORDS	Available onsite?					
RECORDS				Not		
	Yes	No	N/A	Inspected		
Control Mechanism or Permit				\boxtimes		
Monitoring and reporting records for past 3 years	\boxtimes					
Maintenance records				\boxtimes		
Operational records/ log books				\boxtimes		
Spill prevention control and countermeasure (SPCC) plan				\boxtimes		
Slug Control Plan				\boxtimes		
Have any Spills or Slug Loadings occurred?		\boxtimes				
Was notification provided to POTW?			\boxtimes			
Are records available?			\boxtimes			
Notes:						

REPORTS		Completed in time frame and frequency as required by permit?				
				Not		
	Yes	No	N/A	Inspected		
Has IU submitted Semi-annual reports to Control Authority?	\boxtimes					
Other:						
Other:						
Notes: The plant manager stated that he submits monthly reports	to CRSS	SJV.				

III. SELF MONITORING PROGRAM

II. SEE MONTORING FROGRAM					
SAMPLING RECORDS		Yes	No	N/A	Not Inspected
Are monitoring reports submitt required by permit?	ed in timeframe and frequency	\boxtimes			
Sampling Records have: Dates, performing sampling:	times, location, & name of individual	\boxtimes			
Lab Reports have: Analytical me analyses:	ethods, results, dates and time of	\boxtimes			
Are samples collected and present CFR Part 136?	erved using methods approved in 40	\boxtimes			\boxtimes
Detection limits are reported for	r "less than" results:		\boxtimes		
Does discharger monitor effluer Permit?	nt more frequently than required by				\boxtimes
If Yes, is all data collected rep	orted?				\boxtimes
Notes: The results for all metals in the report submitted on June 12, 2023 are "ND". The MDL column is blank for each metal that has "ND" as a result.					
Column is blank for e	ach metal that has "ND" as a result.				
SAMPLE MONITORING	each metal that has "ND" as a result.	Yes	No	N/A	Not Inspected
		Yes	No	N/A	
SAMPLE MONITORING Are sample locations and method	ods representative of Effluent?		-	<i>,</i>	Inspected
SAMPLE MONITORING Are sample locations and method What Flow Measurement Device	ods representative of Effluent? e is utilized?				Inspected
SAMPLE MONITORING Are sample locations and method What Flow Measurement Device □ Flume □	ods representative of Effluent?				Inspected
SAMPLE MONITORING Are sample locations and method What Flow Measurement Device □ Flume □ □ Calculation □	ods representative of Effluent? e is utilized? Weir Meter: Type: Rosem				Inspected
SAMPLE MONITORING Are sample locations and method What Flow Measurement Device □ Flume □ □ Calculation □	ods representative of Effluent? e is utilized? Weir	ount m	agneti	c flow r	Inspected
SAMPLE MONITORING Are sample locations and method What Flow Measurement Device Flume Calculation Device appears to be functioning	ods representative of Effluent? e is utilized? Weir	ount m	agneti	c flow r	Inspected
SAMPLE MONITORING Are sample locations and method What Flow Measurement Device Flume Calculation Device appears to be functionir Is flow meter calibration available	ods representative of Effluent? e is utilized? Weir	ount m	agneti	c flow r	Inspected

					Шэрс	CCIOII De	ate. 1/30/2024
ANALYTICAL MONITORING							Not
				Yes	No	N/A	Inspected
Does discharger perform on-site analymonitoring?	ysis for c	ompliance			\boxtimes		
List parameters analyzed on-site:	,						
Are records of equipment calibration				\boxtimes			
Is the on-site laboratory certified?						\boxtimes	
Certification Number							
Expiration Date							
COMPLIANCE MONITORING RATING	CODE	Satisfactory	Margin	al Unsatisfactory		actory	Not Rated
COMPLIANCE MONITORING RATING	CODE						\boxtimes
Notes:							
IV. SITE REVIEW OPERATIONS AND MA	AINTENA	NCE					
General							Not

IV. SITE REVIEW OPERATIONS AND MAINTENANCE				
General	Yes	No	N/A	Not Inspected
Does the facility appear to have potential for slug discharges (e.g. raw materials / chemicals without secondary containment)?		\boxtimes		
Is there evidence of/possibility for discharge other than at outfalls as described in the permit?		\boxtimes		
Is the facility as described in the permit/fact sheet for the following?				
Processes				\boxtimes
Treatment Units				\boxtimes
Flow and/or Production Rates				\boxtimes
Outfalls & Monitoring Locations	\boxtimes			
Have there been significant changes in operation since last inspection or permit reissuance?	\boxtimes			
Plant schematic is up to date				\boxtimes
Notes: The plant manager stated that they no longer use a boiler, s wastewater. Additionally, the facility was previously owned by Desotec.				

					T
Treatment Units & Supporting Equipment					Not
		Yes	No	N/A	Inspected
Hydraulic and loadings rates appear consistent with the permit and plant design		\boxtimes			
Tanks, floats, pipes, valves, etc. appear in good working condition		\boxtimes			
Equipment appears adequately maintained and functioning correct	:ly	\boxtimes			
There is no visible evidence of hydraulic short-circuiting		\boxtimes			
Process controls appear adequate		\boxtimes			
No safety concerns observed that may interfere with operation, maintenance, monitoring		\boxtimes			
Notes:			1		
Operation & Maintenance		Yes	No	N/A	Not Inspected
O &M Manuals are organized and maintained for use:					
The maintenance activities, spare parts on-hand, and equipment					
available appear adequate to ensure continuous operation of treatment system:					\boxtimes
Is a maintenance management program in place?					\boxtimes
Number of open work orders:					
Oldest date of open work order:					
Notes:					
Stormwater					Not
		Yes	No	N/A	Inspected
Does facility have exposure and potential to discharge Stormwater?	?	\boxtimes			
Is discharger subject to Multi Sector General Permit (MSGP)?		\boxtimes			
If Yes→ Filed Notice of Intent?		\boxtimes			
If Yes → Stormwater Pollution Prevention Plan (SWPPP) available	!				\boxtimes
Is there evidence of unauthorized (non-stormwater) discharges?			\boxtimes		
Are there signs of spills to soil, groundwater, or surface water?			\boxtimes		
Is adequate equipment available for spill cleanup and containment?	?				\boxtimes
Are the following areas observed to be free of materials to prevent					
stormwater pollution?					Not
		Yes	No	N/A	Inspected
Storage areas					
Fueling areas					
Maintenance areas					\boxtimes
Loading and unloading areas		\boxtimes		П	


waste disposal areas				X
Chemicals are stored in secondary containment:	\boxtimes			
Notes:				
V. FINAL EFFLUENT				
EFFLUENT APPEARANCE	Yes	No	N/A	Not Inspected
Clear				\boxtimes
Colorless				\boxtimes
Free of oil sheen				\boxtimes
Free of floatables				\boxtimes
Free of objectionable odor				\boxtimes
Notes:				
VI. SINGLE EVENT VIOLATIONS				
Were any Single Event Violations (SEV) Observed?		'	Yes 🛭	☑ No
If Yes Describe SEV:		S	SEV COD	DE


Appendix 2 – Photograph Log

The photographs were taken during the inspection by Laila Hayani using an Olympus Tough TG-5 digital camera. Original copies of the photos are maintained by EPA Region 9.

Photo 1: First stage reaction tank for pH adjustment (right of photo) and reaction chamber (left of photo)










Photo 4: Clearwell chamber. Floor drains lead to the wastewater treatment system.

Photo 5: Filtration chamber










Photo 7: Sludge press condenses sludge into filter cakes, which are sent off-site for disposal.



Photo 9: Flow meter

